



**Product Approval**  
USER: Public User

[Product Approval Menu](#) > **Application Detail**

► OFFICE OF THE  
SECRETARY

FL #

Application Type

Code Version

Application Status

FL14086-R4

Revision

2020

Approved

Comments

Archived

☐

Product Manufacturer

Address/Phone/Email

Sunoptics Prismatic Skylights

6201 27th Street

Sacramento, CA 95822

(916) 395-4700

james.ernst@acuitybrands.com

Authorized Signature

James Ernst

james.ernst@acuitybrands.com

Technical Representative

Address/Phone/Email

Jim Blomberg

6201 27th Street

Sacramento, CA 95822

(800) 289-4700

highnoon@sunoptics.com

Quality Assurance Representative

Address/Phone/Email

Category

Subcategory

Sky Lights

Skylight

Compliance Method

Evaluation Report from a Florida Registered Architect or a Licensed Florida Professional Engineer

☐ Evaluation Report - Hardcopy Received

Florida Engineer or Architect Name who developed the Evaluation Report

Robert J. Amoruso

Florida License

PE-49752

Quality Assurance Entity

Architectural Testing, Inc., an Intertek Company

Quality Assurance Contract Expiration Date

12/31/2023

Validated By

Steven M. Urich, PE

☒ Validation Checklist - Hardcopy Received

Certificate of Independence

[FL14086\\_R4\\_COI\\_CI\\_1701\\_Rev2\\_ss.pdf](#)

Referenced Standard and Year (of Standard)

**Standard**

**Year**

TAS 201

1994

TAS 202

1994

TAS 203

1994

Equivalence of Product Standards  
Certified By

Florida Licensed Professional Engineer or Architect

[FL14086\\_R4\\_Equiv\\_EER\\_1701\\_Rev2\\_ss.pdf](#)

Sections from the Code

Product Approval Method

Method 1 Option D

Date Submitted 10/24/2020  
Date Validated 10/24/2020  
Date Pending FBC Approval 11/02/2020  
Date Approved 12/15/2020

#### Summary of Products

FL #	Model, Number or Name	Description
14086.1	800MD - Signature	Curb Mount Skylight with Aluminum Frame
<b>Limits of Use</b> <b>Approved for use in HVHZ:</b> Yes <b>Approved for use outside HVHZ:</b> Yes <b>Impact Resistant:</b> Yes <b>Design Pressure:</b> +60/-60 <b>Other:</b> Large Missile Impact Resistant. See Installation Drawing for size and anchorage requirements.		<b>Installation Instructions</b> <a href="#">FL14086_R4_II_SUN0002_RevB_ss.pdf</a> Verified By: Robert J. Amoruso, P.E. FL PE Lic. No. 49752 Created by Independent Third Party: Yes <b>Evaluation Reports</b> <a href="#">FL14086_R4_AE_PER_1701_Rev2_ss.pdf</a> Created by Independent Third Party: Yes

[Back](#)

[Next](#)

[Contact Us](#) :: [2601 Blair Stone Road, Tallahassee FL 32399](#) Phone: 850-487-1824

The State of Florida is an AA/EEO employer. [Copyright 2007-2013 State of Florida](#). :: [Privacy Statement](#) :: [Accessibility Statement](#) :: [Refund Statement](#)

Under Florida law, email addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact the office by phone or by traditional mail. If you have any questions, please contact 850.487.1395. \*Pursuant to Section 455.275(1), Florida Statutes, effective October 1, 2012, licensees licensed under Chapter 455, F.S. must provide the Department with an email address if they have one. The emails provided may be used for official communication with the licensee. However email addresses are public record. If you do not wish to supply a personal address, please provide the Department with an email address which can be made available to the public. To determine if you are a licensee under Chapter 455, F.S., please click [here](#).

#### Product Approval Accepts:

